

НАЦИОНАЛЬНАЯ СИСТЕМА ПОДТВЕРЖДЕНИЯ СООТВЕТСТВИЯ РЕСПУБЛИКИ БЕЛАРУСЬ

Аккредитованный орган по сертификации



РУП «Институт БелНИИС»

220114, г. Минск, ул. Ф. Скорины, 15 Б,

тел. 267-27-33, тел./факс 267-90-94,

(аттестат аккредитации №BY/112 088.01, дата регистрации 08.09.2008)

СЕРТИФИКАТ СООТВЕТСТВИЯ

Зарегистрирован в Реестре № BY/112 02.01. 088 00997



Дата регистрации 01 августа 2016 г.

Действителен до 01 августа 2021 г.

Настоящий сертификат удостоверяет, что идентифицированная должным образом продукция, изготовленная Обществом с ограниченной ответственностью «Алютех Воротные Системы», Республика Беларусь, 220075, Минская обл., Минский р-н, СЭЗ «Минск», ул. Селицкого, д. 10, 508

и представленная на сертификацию под наименованием Ворота откатные серии ОС, выпускаемые по ТУ РБ 101452725.001-2000

Серийное производство

код ОКП РБ – 25.12.10

код ТН ВЭД ТС – 7308 30 000 0, 7610 10 000 0
8479 89 970 8

соответствует требованиям

ТР 2009/013/BY «Здания и сооружения, строительные материалы и изделия. Безопасность», ГОСТ EN 13241-1-2015 «Ворота. Часть 1. Изделия с ненормируемыми огнестойкостью и дымопроницаемостью» п.п. 4.2.3, 4.2.8, 4.3.3, 4.4.3.

Заявитель (изготовитель, продавец) Общество с ограниченной ответственностью «Алютех Воротные Системы», 220075, Минская обл., Минский р-н, СЭЗ «Минск», ул. Селицкого, д. 10, 508.

код УНП - 808001246

Сертификат соответствия выдан на основании:

а) документов акта анализа состояния производства от 02.02.2016; свидетельства о технической компетентности № 05891370.672-2016 от 01.06.2016;

б) протокола испытаний протокола испытаний от 20.12.2013 № 1020-CPR-090-030740 Technical and Test Institute for Construction Prague, Чехия.

Инспекционный контроль осуществляет РУП «Институт БелНИИС».

Особые отметки

Срок хранения сертификата у заявителя - пять лет после истечения срока его действия.

Дополнительная информация -

Зам. руководителя аккредитованного
органа по сертификации

Эксперт-аудитор



Н.Б. Сучков

С.В. Календо

№ 0076647

CONSTRUCTION PRODUCTS REGULATION

Declaration of Performance

(REGULATION (EU) No 305/2011, ANNEX III)

№OC/2014

1. Identification code: **Entrance sliding gates series ADS 400, trade mark ALUTECH**
2. Type: **OC**
3. Intended use: **external door for vehicle access**
4. Manufacturer: **Alutech Door Systems LLC**, Selitskogo str., 10-508, 220075, FEZ «Minsk», Minsk region, Minsk area, Republic of Belarus
5. Authorised representative: **Alutech Systems s.r.o.**, CTPark Bor, Nova Hospoda 19, 348 02 Bor u Tachova, Czech Republic
6. Assessment and verification of constancy of performance: **System 3**
7. Relevant harmonised standard: **EN 13241-1:2003+ A1:2011**

Technical and Testing Institute for Constructions Prague, branch Prague (Czech Republic), NB 1020 performed Initial Type Testing (ITT) under system 3 and issued Report on the ITT No. 1020-CPD-090-030740 from 20.12.2013

8. European Technical Assessment: **Not applicable**
9. Declared performance

Essential Characteristics	Performance	Harmonised technical specification
Watertightness	npd	EN 13241-1:2003+ A1:2011
Release of dangerous	none	
Resistance to wind load	class 3	
Thermal resistance	npd	
Air permeability	npd	
Safe operating	pass	
Mechanical resistance and stability	pass	
Operating forces (for power operated doors)	pass	
Durability of the performance characteristics	npd	

Specific Technical Documentation: **Not applicable**

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Sergey Kogolenok – Director

(name and function)

Minsk, 13/01/2014

(place and date of issue)



(signature)



® **TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.**

Technical and Test Institute for Construction Prague

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznámený subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán / Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body. Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Notified Body 1020

Branch 0900 – Technical Engineering Services

REPORT

on the determination of the product-type

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), Art. 1.4 of the Annex V

No. 1020 – CPR – 090-030740

Trade name:

Sliding gate, series "OC", EN 13241-1:2011

(Entrance gates series ADS 400, trade mark ALUTECH type OC)

type / variations: sliding gate, type "OC" (maximum supplied dimensions: W = 5 m, H = 3.21 m)

Manufacturer:

Alutech Door Systems LLC

Company Registration No.: 808001246

Factual Address: 4-4, Inzhenernaya str., Minsk, Belarus, 220075

Plant: Alutech Door Systems LLC

Legal Address: 10-508, Selitskogo str., Minsk area, Minsk region, FEZ «Minsk», Republic of Belarus, 220075

Order (TZÚS – TIS): Z 090 13 0296 (928)

Number of Report pages, including title page: 5

Number of Annex 4

Person taking responsibility for the content of this report:

– Milan Kutilek
Head Assessor

Person taking responsibility for the correctness of this report:

Jiří Studnička
Deputy Manager of Notified Body 1020

Stamp of Notified Body 1020

Prague, 20. December 2013



Note: This Report shall not be reproduced other than in whole without the written consent of the Assistant Director of the Authorized Body.

Technický a zkušební ústav stavební Praha, s. p., Branch 0900-TIS, Prosecká 811/76a, 190 00 Prague 9, Czech Republic
Tel.: 286 019 400, fax: +420 286 881 995, http: +420 286 019 400, email: jstudnic@tzus.cz, www.tzus.cz
Bank: KB Praha 1 Czech Republic, acc. No.: 1501-931/0100, Reg. No.: 000 15679, VAT No.: 009-00015679

Initial type test - Overview of test results

Property	Test Report	Test procedure	Required/declared level	Measured value
1. Watertight integrity			NPD	
2. Release of hazardous substances clause 4.2.9 in ČSN EN 13241-1			NPD	
3. Resistance to wind load	Static calculation of wind resistance (Annex 4)	ČSN EN 12424	Class "3"	Class "3" See Annex 4 - Static calculation of wind resistance
4. Heat transfer coefficient			NPD	
5. Air permeability			NPD	
6. Durability of watertight integrity, heat transfer coefficient and air permeability			NPD	
7. Safety of openings clause 4.2.8 in ČSN EN 13241-1 (or clause 5.3.2 in ČSN EN 12605)	Report No. 090-029833 (Annex 1)	clauses 5.3.2 and 5.4.3 ČSN EN 12605 clauses 5.1.2 and 5.4.2 ČSN EN 12605	verification based on the test guideline	See Report No. 090-029833/1963
8. Operating forces clause 4.3.3 in ČSN EN 13241-1 (or clause 5.2.4.1 in ČSN EN 12445)	Report No. 090-029833 (Annex 1)	clauses 5.1.1, 5.1.3, 5.1.1.4 ČSN EN 12453 and for safety devices clause 5.1.1.6 in ČSN EN 12453 ČSN EN 12978	Forces on closing edge $F_{max} < 400N$ $F_{stat} < 150N$ $T_{dyn} \leq 0.75s$ $T_{stat} \leq 5s$	See Report No. 090-029833/1963



4 Annexes

- Annex 1. Test Report No. 090-029833/1963
- Annex 2. Sliding gate – test sample – photograph
- Annex 3. Types of contact ledges of the gates
- Annex 4. Static calculation of wind resistance

END OF REPORT